

R134a sobrecalentado MEC 2254 DOCENTE: EDGAR S. PEÑARANDA M. UTO FNI pag1

p=0.6 Bar					p=1Bar				
T(°C)	v	u	h	s	T(°C)	v	u	h	s
-20.0	0.3361	220.6	240.8	1.017	-20.0	0.1984	219.7	239.5	0.9721
-7.8	0.3537	229.1	250.3	1.054	-7.8	0.2094	228.3	249.3	1.01
4.4	0.3711	237.9	260.1	1.09	4.4	0.2202	237.2	259.2	1.046
16.7	0.3883	246.9	270.2	1.126	16.7	0.2308	246.3	269.4	1.082
28.9	0.4055	256.1	280.4	1.161	28.9	0.2414	255.6	279.7	1.117
41.1	0.4226	265.6	290.9	1.195	41.1	0.2518	265.1	290.3	1.152
53.3	0.4396	275.3	301.7	1.228	53.3	0.2622	274.9	301.1	1.185
65.6	0.4565	285.3	312.7	1.261	65.6	0.2725	284.9	312.2	1.219
77.8	0.4734	295.5	323.9	1.294	77.8	0.2828	295.2	323.5	1.251
90.0	0.4903	306	335.4	1.326	90.0	0.293	305.7	335	1.284

p=1.4Bar					p=1.8Bar				
T(°C)	v	u	h	s	T(°C)	v	u	h	s
-10.0	0.1461	225.9	246.4	0.9724	-10.0	0.1119	225	245.2	0.9484
2.2	0.1541	234.9	256.4	1.01	2.2	0.1184	234.1	255.4	0.9867
14.4	0.1619	244	266.7	1.046	14.4	0.1247	243.4	265.8	1.024
26.7	0.1696	253.3	277.1	1.082	26.7	0.1308	252.8	276.4	1.059
38.9	0.1773	262.9	287.7	1.116	38.9	0.1369	262.4	287.1	1.094
51.1	0.1848	272.7	298.6	1.15	51.1	0.1428	272.3	298	1.129
63.3	0.1923	282.7	309.6	1.184	63.3	0.1488	282.3	309.1	1.162
75.6	0.1997	293	320.9	1.217	75.6	0.1546	292.6	320.4	1.195
87.8	0.2071	303.5	332.4	1.249	87.8	0.1604	303.1	332	1.228
100.0	0.2145	314.2	344.2	1.281	100.0	0.1662	313.9	343.8	1.26

p=2Bar					p=2.4Bar				
T(°C)	v	u	h	s	T(°C)	v	u	h	s
-5.0	0.1024	228.3	248.8	0.9541	-5.0	0.08406	227.4	247.6	0.9358
6.7	0.108	237.1	258.7	0.9903	6.7	0.08891	236.4	257.8	0.9728
18.3	0.1134	246.1	268.7	1.025	18.3	0.09358	245.4	267.9	1.008
30.0	0.1187	255.1	278.9	1.06	30.0	0.09812	254.6	278.2	1.043
41.7	0.124	264.4	289.2	1.093	41.7	0.1026	263.9	288.6	1.077
53.3	0.1291	273.9	299.7	1.126	53.3	0.1069	273.4	299.1	1.109
65.0	0.1342	283.5	310.4	1.158	65.0	0.1113	283.1	309.8	1.142
76.7	0.1393	293.4	321.3	1.189	76.7	0.1155	293	320.8	1.174
88.3	0.1443	303.5	332.3	1.221	88.3	0.1198	303.1	331.9	1.205
100.0	0.1493	313.7	343.6	1.251	100.0	0.124	313.4	343.2	1.236

p=2.8Bar					p=3.2Bar				
T(°C)	v	u	h	s	T(°C)	v	u	h	s
5	0.07466	234.4	255.3	0.9523	5.0	0.06445	233.6	254.2	0.9384
17.78	0.0792	244.4	266.6	0.9919	17.8	0.06856	243.7	265.7	0.9787
30.56	0.08356	254.5	277.9	1.03	30.6	0.07248	254	277.1	1.017
43.33	0.08782	264.8	289.4	1.067	43.3	0.07628	264.3	288.7	1.055
56.11	0.09199	275.3	301.1	1.103	56.1	0.07999	274.9	300.5	1.091
68.89	0.09609	286	313	1.139	68.9	0.08363	285.7	312.4	1.127
81.67	0.1001	297	325	1.173	81.7	0.08722	296.7	324.6	1.162
94.44	0.1041	308.2	337.4	1.208	94.4	0.09076	307.9	336.9	1.196
107.2	0.1081	319.6	349.9	1.241	107.2	0.09427	319.4	349.5	1.229
120	0.1121	331.3	362.7	1.274	120.0	0.09775	331.1	362.3	1.263

v=(m³/kg), u=(KJ/kg), h=(KJ/kg), s=(KJ/kg-k)

R134a sobrecalentado MEC 2254 DOCENTE: EDGAR S. PEÑARANDA M. UTO FNI pag2

p=4Bar					p=5Bar				
T(°C)	v	u	h	s	T(°C)	v	u	h	s
10	0.05151	236	256.6	0.9305					
24.44	0.05537	247.8	270	0.9766	24.4	0.04312	246.2	267.7	0.9527
38.89	0.05902	259.7	283.3	1.02	38.9	0.04622	258.3	281.4	0.9977
53.33	0.06252	271.7	296.7	1.062	53.3	0.04917	270.6	295.1	1.041
67.78	0.06593	284	310.3	1.103	67.8	0.052	283	309	1.082
82.22	0.06926	296.5	324.2	1.143	82.2	0.05475	295.6	323	1.122
96.67	0.07253	309.3	338.3	1.182	96.7	0.05744	308.5	337.2	1.162
111.1	0.07575	322.3	352.6	1.22	111.1	0.06008	321.7	351.7	1.2
125.6	0.07894	335.7	367.3	1.257	125.6	0.06268	335.1	366.4	1.238
140	0.0821	349.4	382.2	1.294	140.0	0.06526	348.8	381.5	1.275

p=6 Bar					p=7Bar				
T(°C)	v	u	h	s	T(°C)	v	u	h	s
30.0	0.03598	249.2	270.8	0.9499	30.0	0.02997	247.5	268.5	0.9313
44.4	0.03867	261.7	284.9	0.9953	44.4	0.03243	260.3	283	0.9782
58.9	0.0412	274.2	298.9	1.038	58.9	0.03471	273	297.3	1.022
73.3	0.04362	286.8	313	1.08	73.3	0.03686	285.8	311.6	1.064
87.8	0.04596	299.7	327.3	1.12	87.8	0.03894	298.8	326.1	1.105
102.2	0.04825	312.8	341.7	1.16	102.2	0.04095	312	340.7	1.145
116.7	0.05049	326.1	356.4	1.198	116.7	0.04291	325.4	355.5	1.184
131.1	0.05269	339.7	371.3	1.236	131.1	0.04484	339.1	370.5	1.221
145.6	0.05486	353.6	386.5	1.273	145.6	0.04673	353.1	385.8	1.259
160.0	0.05701	367.8	402	1.309	160.0	0.0486	367.3	401.3	1.295

p=8Bar					p=9Bar				
T(°C)	v	u	h	s	T(°C)	v	u	h	s
40.0	0.02704	254.8	276.4	0.948	40.0	0.02337	253.1	274.2	0.9327
55.6	0.02935	268.8	292.3	0.9975	55.6	0.02556	267.5	290.5	0.9837
71.1	0.03149	282.8	308	1.044	71.1	0.02755	281.7	306.5	1.031
86.7	0.03352	296.9	323.7	1.089	86.7	0.02942	296	322.5	1.077
102.2	0.03547	311.2	339.6	1.132	102.2	0.0312	310.4	338.5	1.12
117.8	0.03736	325.8	355.7	1.174	117.8	0.03292	325.1	354.7	1.162
133.3	0.03921	340.6	372	1.215	133.3	0.0346	340	371.1	1.204
148.9	0.04102	355.8	388.6	1.255	148.9	0.03623	355.2	387.8	1.244
164.4	0.0428	371.2	405.4	1.294	164.4	0.03784	370.7	404.8	1.283
180.0	0.04455	387	422.6	1.333	180.0	0.03942	386.5	422	1.322

p=10Bar					p=12Bar				
T(°C)	v	u	h	s	T(°C)	v	u	h	s
40.0	0.02041	251.3	271.7	0.9179					
55.6	0.02251	266.2	288.7	0.9708	55.6	0.01789	263.2	284.7	0.9463
71.1	0.02439	280.6	305	1.019	71.1	0.01962	278.3	301.8	0.9973
86.7	0.02613	295	321.2	1.065	86.7	0.02119	293.1	318.5	1.045
102.2	0.02778	309.6	337.4	1.109	102.2	0.02265	307.9	335.1	1.09
117.8	0.02937	324.3	353.7	1.152	117.8	0.02403	322.9	351.7	1.133
133.3	0.03091	339.3	370.2	1.193	133.3	0.02537	338	368.5	1.175
148.9	0.03241	354.6	387	1.234	148.9	0.02666	353.4	385.4	1.216
164.4	0.03387	370.2	404	1.274	164.4	0.02792	369.1	402.6	1.256
180.0	0.03532	386	421.4	1.312	180.0	0.02916	385.1	420.1	1.295

v=(m³/kg), u=(KJ/kg), h=(KJ/kg), s=(KJ/kg-k)

R134a sobrecalentado MEC 2254 DOCENTE: EDGAR S. PEÑARANDA M. UTO FNI pag3

p=14Bar					p=16Bar				
T(°C)	v	u	h	s	T(°C)	v	u	h	s
60	0.01501	264.5	285.5	0.9389	60.0	0.01237	260.9	280.7	0.9163
73.33	0.01639	277.9	300.9	0.9842	73.3	0.01375	275.2	297.2	0.9651
86.67	0.01763	291	315.7	1.026	86.7	0.01494	288.8	312.7	1.009
100	0.01878	304	330.3	1.066	100.0	0.01601	302.1	327.8	1.05
113.3	0.01986	317	344.8	1.104	113.3	0.01702	315.4	342.6	1.089
126.7	0.0209	330.1	359.4	1.141	126.7	0.01797	328.7	357.4	1.127
140	0.0219	343.3	374	1.177	140.0	0.01888	342	372.3	1.163
153.3	0.02288	356.7	388.8	1.212	153.3	0.01976	355.6	387.2	1.199
166.7	0.02383	370.3	403.7	1.247	166.7	0.02062	369.2	402.2	1.234
180	0.02476	384.1	418.8	1.281	180.0	0.02146	383.1	417.4	1.268

v=(m³/kg), u=(KJ/kg), h=(KJ/kg), s=(KJ/kg-k)